PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Abstracta
Object:	Bits Wall XL
Size [mm]:	w=100 h=649 d=748

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.000
125	0.080
250	0.150
500	0.240
1000	0.280
2000	0.260
4000	0.230

N_{10} = 43



ORIGINAL TEST REPORT	DATE OF REPORT
-	-