



# PRODUCT DECLARATION

## SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Abstracta
<b>Object:</b>	Bits Wall XL
<b>Size [mm]:</b>	w=100 h=649 d=748

### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.00
125	0.08
250	0.15
500	0.24
1000	0.28
2000	0.26
4000	0.23

N<sub>10</sub> = 43

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

