



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Abstracta
Object:	Bits Wall XL
Size [mm]:	w=100 h=649 d=748

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.00
125	0.08
250	0.15
500	0.24
1000	0.28
2000	0.26
4000	0.23

N₁₀ = 43

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

