



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Abstracta
Object:	Basic Baffle (Parallel, 25 cm distance in between)
Size [mm]:	w=30 h=650 d=1200

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.00
125	0.30
250	0.40
500	0.60
1000	0.80
2000	0.90
4000	0.80

N₁₀ = 17

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

