



# PRODUCT DECLARATION

## SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

<b>Producer:</b>	Abstracta
<b>Object:</b>	Holly lighting, vertical
<b>Size [mm]:</b>	w=540 h=585 d=883

### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	1/3 Octave Band	Octave Band
100	-0.05	
125	0.20	0.18
160	0.39	
200	0.38	
250	0.56	0.54
315	0.67	
400	0.94	
500	0.89	0.91
630	0.89	
800	0.70	
1000	0.72	0.72
1250	0.74	
1600	0.74	
2000	0.86	0.81
2500	0.82	
3150	0.81	
4000	0.87	0.84
5000	0.84	

Equivalent sound absorption area per unit



N<sub>10</sub> = 14

ORIGINAL TEST REPORT	DATE OF REPORT
20220608.2	2023-04-20

