



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Abstracta
<b>Object:</b>	dB Modular Sofa
<b>Size [mm]:</b>	w=620 h=860 d=1500

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.00
125	1.90
250	2.60
500	3.10
1000	3.80
2000	4.00
4000	3.90

N<sub>10</sub> = 3.2

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

