



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


| | |
|-------------------|-------------------|
| Producer: | Abstracta |
| Object: | Moon lighting |
| Size [mm]: | w=550 h=525 d=525 |

Equivalent sound absorption area per unit (m² Sabine)

| f(Hz) | Octave Band |
|-------|-------------|
| 63 | 0.00 |
| 125 | 0.27 |
| 250 | 0.51 |
| 500 | 0.61 |
| 1000 | 0.68 |
| 2000 | 0.76 |
| 4000 | 0.88 |

N₁₀ = 16

Equivalent sound absorption area per unit



| | |
|-----------------------------|-----------------------|
| ORIGINAL TEST REPORT | DATE OF REPORT |
| - | - |

