



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Götessons, Akustikmiljö / Am Acoustics
Object:	Cobogo (12 units)
Size [mm]:	w=5 h=372 d=372

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.00
125	0.03
250	0.07
500	0.19
1000	0.43
2000	0.67
4000	0.89

N₁₀ = 53

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

