



# PRODUCT DECLARATION

## SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Götessons, Akustikmiljö / Am Acoustics
<b>Object:</b>	Cobogo (12 units)
<b>Size [mm]:</b>	w=5 h=372 d=372

### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.00
125	0.03
250	0.07
500	0.19
1000	0.43
2000	0.67
4000	0.89

N<sub>10</sub> = 53

### Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

