



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Decibel AB
Object:	Clamp Floor
Size [mm]:	w=45 h=1700 d=1200

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.49
125	0.78
250	1.60
500	2.70
1000	3.50
2000	3.40
4000	3.60

N₁₀ = 3.7

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT

DATE OF REPORT

