



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Decibel AB
Object:	Clamp Ceiling
Size [mm]:	w=50 h=600 d=600

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.02
125	0.09
250	0.19
500	0.45
1000	0.52
2000	0.54
4000	0.61

N₁₀ = 22

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT

DATE OF REPORT

