



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Decibel AB
Object:	Clamp Wall Round
Size [mm]:	w=40 h=0 d=600

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.02
125	0.06
250	0.20
500	0.50
1000	0.50
2000	0.42
4000	0.38

N₁₀ = 26

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

