



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Decibel AB
Object:	Clamp Wall Square
Size [mm]:	w=40 h=600 d=600

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.20
125	0.09
250	0.27
500	0.51
1000	0.54
2000	0.49
4000	0.44

N₁₀ = 23

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

