



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Decibel AB
Object:	Hertz Floor
Size [mm]:	w=45 h=1200 d=800

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.24
125	0.38
250	0.79
500	1.30
1000	1.80
2000	1.80
4000	1.80

N₁₀ = 7.7

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT

DATE OF REPORT

