PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Kinnarps
Object:	Vibe (desk screen)
Size [mm]:	w=40 h=650 d=840

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.11
125	0.22
250	0.41
500	0.58
1000	0.72
2000	0.78
4000	0.87

N_{10} = 17



ORIGINAL TEST REPORT	DATE OF REPORT
-	-