



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Kinnarps
Object:	Vibe (floor screen)
Size [mm]:	w=40 h=1200 d=1165

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.30
125	0.40
250	1.10
500	1.60
1000	2.00
2000	2.20
4000	2.40

N₁₀ = 6.3

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

