



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Götessons
Object:	Moving Wall Tower
Size [mm]:	w=450 h=1800 d=1650

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	1.60
125	3.10
250	4.00
500	4.10
1000	4.50
2000	4.90
4000	5.20

N₁₀ = 2.4

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
21-705-M1	2021-02-22

