



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Götessons
<b>Object:</b>	Moving Wall Media
<b>Size [mm]:</b>	w=450 h=1800 d=1650

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	1.20
125	2.20
250	3.20
500	3.20
1000	3.60
2000	4.20
4000	4.90

N<sub>10</sub> = 3.1

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
21-705-M3	2021-02-22

