PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Götessons
Object:	Moving Wall Media
Size [mm]:	w=450 h=1800 d=1650

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	1.20
125	2.20
250	3.20
500	3.20
1000	3.60
2000	4.20
4000	4.90

N_{10} = 3.1



ORIGINAL TEST REPORT	DATE OF REPORT
21-705-M3	2021-02-22