



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Götessons
<b>Object:</b>	ScreenIT Silent
<b>Size [mm]:</b>	w=32 h=650 d=800

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.15
125	0.25
250	0.31
500	0.42
1000	0.52
2000	0.58
4000	0.67

N<sub>10</sub> = 24

#### Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

