



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Abstracta
Object:	Trumpet 1040
Size [mm]:	w=80 h=1040 d=515

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.08
125	0.10
250	0.40
500	0.50
1000	0.50
2000	0.50
4000	0.60

N₁₀ = 20

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

