PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Abstracta
Object:	dB Pillar 1930
Size [mm]:	w=369 h=470 d=1930

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.61
125	1.26
250	1.82
500	2.50
1000	2.75
2000	2.75
4000	3.37

N_{10} = 4



ORIGINAL TEST REPORT	DATE OF REPORT
-	-