



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Abstracta
Object:	dB Pillar 700
Size [mm]:	w=369 h=470 d=700

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.30
125	0.66
250	0.77
500	0.88
1000	1.02
2000	1.04
4000	1.14

N₁₀ = 11

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT

DATE OF REPORT

