



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Offecct
Object:	Soundsticks® Cluster
Size [mm]:	w=95 h=95 d=1240 Total Construction Height=700.00

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.10
125	0.10
250	0.60
500	1.40
1000	2.10
2000	2.50
4000	2.60

N₁₀ = 7.1

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

