



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Offecct
Object:	Soundsticks®
Size [mm]:	w=95 h=95 d=1240

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.01
125	0.03
250	0.07
500	0.17
1000	0.28
2000	0.34
4000	0.38

N₁₀ = 57

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

