



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Offecct
<b>Object:</b>	Soundsticks®
<b>Size [mm]:</b>	w=95 h=95 d=1240

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.01
125	0.03
250	0.07
500	0.17
1000	0.28
2000	0.34
4000	0.38

N<sub>10</sub> = 57

#### Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

