



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


| | |
|-------------------|--------------------------|
| Producer: | Abstracta |
| Object: | Softline 50 Floor Screen |
| Size [mm]: | w=50 h=1360 d=800 |

Equivalent sound absorption area per unit (m² Sabine)

| f(Hz) | Octave Band |
|-------|-------------|
| 63 | 0.20 |
| 125 | 0.30 |
| 250 | 0.90 |
| 500 | 1.50 |
| 1000 | 1.80 |
| 2000 | 1.80 |
| 4000 | 1.90 |

N₁₀ = 6.7

Equivalent sound absorption area per unit



| | |
|-----------------------------|-----------------------|
| ORIGINAL TEST REPORT | DATE OF REPORT |
| - | - |

