PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Abstracta
Object:	Scala Hanging
Size [mm]:	w=20 h=1600 d=1207

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.00
125	0.84
250	1.35
500	2.22
1000	3.06
2000	3.68
4000	3.69

N_{10} = 4.5



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

Acoustic Facts Scandinavia AB
Kinnegatan 23, 531 33 Lidköping