PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Abstracta
Object:	Scala Wall
Size [mm]:	w=20 h=1600 d=1207 Total Construction Height=35.00

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.00
125	0.21
250	0.77
500	1.94
1000	2.29
2000	1.91
4000	2.19

N_{10} = 5.2



ORIGINAL TEST REPORT	DATE OF REPORT
-	-