



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Abstracta
Object:	My Hive
Size [mm]:	w=3000 h=1300 d=1000

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.00
125	2.31
250	3.29
500	4.47
1000	5.13
2000	5.27
4000	5.40

N₁₀ = 2.2

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

