



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Abstracta
<b>Object:</b>	Airleaf 10 pcs
<b>Size [mm]:</b>	w=20 h=1300 d=900

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.00
125	0.00
250	0.00
500	0.19
1000	0.43
2000	0.89
4000	1.14

N<sub>10</sub> = 53

#### Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
KTH-MWL LW201609_R3	2016-09-23

