



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Abstracta
Object:	Airleaf 10 pcs
Size [mm]:	w=20 h=1300 d=900

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.00
125	0.00
250	0.00
500	0.19
1000	0.43
2000	0.89
4000	1.14

N₁₀ = 53

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
KTH-MWL LW201609_R3	2016-09-23

