PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Abstracta
Object:	Airleaf 10 pcs
Size [mm]:	w=20 h=1300 d=900

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.000
125	0.000
250	0.000
500	0.190
1000	0.430
2000	0.890
4000	1.140

N_{10} = 53



ORIGINAL TEST REPORT	DATE OF REPORT
KTH-MWL LW201609_R3	2016-09-23