PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Abstracta
Object:	Airbloom 10 pcs
Size [mm]:	w=50 h=2325 d=912

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.000
125	0.150
250	0.450
500	0.900
1000	1.500
2000	1.800
4000	2.100

N_{10} = 11



ORIGINAL TEST REPORT	DATE OF REPORT
17-094-M12	2017-05-30