



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Abstracta
Object:	Airbloom 10 pcs
Size [mm]:	w=50 h=2325 d=912

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.00
125	0.05
250	0.15
500	0.30
1000	0.50
2000	0.60
4000	0.70

N₁₀ = 33

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

