



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Abstracta
Object:	Aircone 10 pcs
Size [mm]:	w=43 h=1206 d=928

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.02
125	0.10
250	0.50
500	0.90
1000	0.90
2000	0.90
4000	0.80

N₁₀ = 13

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

