PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Abstracta
Object:	Aircone 10 pcs
Size [mm]:	w=43 h=1206 d=928 Total Construction Height=143

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.020
125	0.100
250	0.500
500	0.900
1000	0.900
2000	0.900
4000	0.800

N_{10} = 13



ORIGINAL TEST REPORT	DATE OF REPORT
13-137-M7	2013-11-12