PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Abstracta
Object:	Lily
Size [mm]:	w=10 h=1200 d=1200

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.100
125	0.200
250	0.500
500	0.900
1000	1.200
2000	1.700
4000	2.100

N_{10} = 11



ORIGINAL TEST REPORT	DATE OF REPORT
17-360-M8	2018-01-23