



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Abstracta
Object:	dB Floor Screen
Size [mm]:	w=30 h=1500 d=800

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.20
125	0.30
250	0.70
500	1.20
1000	1.50
2000	1.50
4000	1.60

N₁₀ = 8.3

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

