



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Götessons
<b>Object:</b>	THE HUT WITH FRONT SCREENS AND DOOR
<b>Size [mm]:</b>	w=1800 h=2270 d=1880

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	4.70
125	3.60
250	7.40
500	8.80
1000	9.70
2000	10.60
4000	11.90

N<sub>10</sub> = 1.1

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
17-321-M2	2017-12-04

