



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Götessons
Object:	Hang Over
Size [mm]:	w=130 h=690 d=810

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.10
125	0.10
250	0.30
500	0.60
1000	0.80
2000	0.90
4000	1.00

N₁₀ = 17

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

