



# PRODUCT DECLARATION

## SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Götessons
<b>Object:</b>	Hang Over
<b>Size [mm]:</b>	w=130 h=690 d=810

### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.10
125	0.10
250	0.30
500	0.60
1000	0.80
2000	0.90
4000	1.00

N<sub>10</sub> = 17

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

