



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Götessons, Akustikmiljö / Am Acoustics
Object:	Honey 8 pcs
Size [mm]:	w=50 h=1560 d=1950

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.20
125	0.50
250	1.20
500	2.00
1000	2.30
2000	2.30
4000	2.00

N₁₀ = 5

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
17-321-M11	2017-11-21

