



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Götessons
Object:	HALF A HUT
Size [mm]:	w=900 h=2270 d=1880

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	2.40
125	2.40
250	5.50
500	6.90
1000	8.10
2000	8.80
4000	9.70

N₁₀ = 1.4

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
17-321-M5	2017-12-04

