



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Götessons
<b>Object:</b>	HALF A HUT
<b>Size [mm]:</b>	w=900 h=2270 d=1880

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	2.40
125	2.40
250	5.50
500	6.90
1000	8.10
2000	8.80
4000	9.70

N<sub>10</sub> = 1.4

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
17-321-M5	2017-12-04

