



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Götessons
Object:	HALF A HUT WITH FRONT SCREENS AND DOOR
Size [mm]:	w=970 h=2270 d=1880

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	2.60
125	2.70
250	5.20
500	6.50
1000	7.20
2000	8.00
4000	9.40

N₁₀ = 1.5

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
17-321-M7	2017-12-04

