



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Götessons
<b>Object:</b>	HALF A HUT WITH FRONT SCREENS AND DOOR
<b>Size [mm]:</b>	w=970 h=2270 d=1880

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	2.60
125	2.70
250	5.20
500	6.50
1000	7.20
2000	8.00
4000	9.40

N<sub>10</sub> = 1.5

#### Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
17-321-M7	2017-12-04

