PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Abstracta
Object:	Stitch Table
Size [mm]:	w=85 h=650 d=860

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.100
125	0.300
250	0.700
500	0.900
1000	1.000
2000	1.000
4000	0.900

N_{10} = 11



ORIGINAL TEST REPORT	DATE OF REPORT
-	-