



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Abstracta
<b>Object:</b>	Scala Table
<b>Size [mm]:</b>	w=60 h=600 d=1800

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.10
125	0.20
250	0.70
500	1.10
1000	1.50
2000	1.70
4000	1.90

N<sub>10</sub> = 9.1

#### Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

