



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Götessons, Akustikmiljö / Am Acoustics
<b>Object:</b>	Vertikal
<b>Size [mm]:</b>	w=130 h=2400 d=3000 Total Construction Height=35.00

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.40
125	1.10
250	2.80
500	3.80
1000	3.70
2000	4.60
4000	5.50

N<sub>10</sub> = 2.7

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
16-239-M20	2016-12-14

